



IMPROVEMENT PERMIT

Davie County Health Department

210 Hospital Street

P.O. Box 848

Mocksville

NC

27028

Phone: 336-753-6780 Fax: 336-753-1680

For Office Use Only

*CDP File Number 359357 - 1

County ID Number: 5728067335

Evaluated For: **NEW**

Township: Callahan

PERMIT VALID UNTIL: 7/21/2026

***NOTE TO INSPECTIONS DIVISION: Building Permits cannot be issued with this Improvement Permit.**

Applicant: Allen Fausch Jr

Address: 7291 Shallowfordd Road

City: Lewisville

State/Zip: NC 27023

Phone #: (336) 408-5060

Property Owner: Jerry Murdock

Address: 2 Charter Place

City: Thomasville

State/Zip: NC 27360

Phone #:

Property Location & Site Information

Address/Road #:

Subdivision: Hawks Landing

Phase:

Lot: 3

Hawks Trail

Mocksville NC 27028

Directions

664 West

TL onto Greenhill Rd

TR McAllister Rd

TR onto Hawks Trail

Structure: SINGLE FAMILY

of Bedrooms: ~~4~~ *aw*

of People: 4 *7/21/21*

*Water Supply: NEW WELL

System Specifications

Initial System

*Site Classification: Provisionally Suitable

Saprolite System? ☐ Yes ☒ No

Design Flow: 4 8 0

Soil Application Rate: 0 . 2 2 5

*System Classification/Description:
TYPE III G. OTHER NON-CONV. TRENCH SYSTEMS

*Proposed System: 25% REDUCTION

Minimum Trench Depth: 3 4 Inches

Maximum Trench Depth: 3 6 Inches

Septic Tank: 1 0 0 0 Gallons

1-Piece: ☐ Yes ☐ No

Pump Required: ☐ Yes ☐ No ☒ May Be Required

Pump Tank: Gallons

1-Piece: ☐ Yes ☐ No

Repair System Required: ☒ Yes ☐ No ☐ No, but has Available Space

Repair System

*Site Classification: Provisionally Suitable

Soil Application Rate: 0 . 2 2 5

*System Classification/Description:
TYPE III G. OTHER NON-CONV. TRENCH SYSTEMS

*Proposed System: 50% REDUCTION

Minimum Trench Depth: 4 4 Inches

Maximum Trench Depth: 4 6 Inches

Pump Required: ☐ Yes ☐ No ☒ May be Required

